



CONTRLR (SIEMENS)

Flow Control Maintains Room dP via Offset
 Example:
 1200 cfm SUPPLY
 - 1100 cfm EXHAUST

 100 cfm OVERSUPPLY
 (room is positive pressure)

CODE COMPLIANT 6 ACH
 OCCUPIED

CODE COMPLIANT 4 ACH
 UNOCCUPIED

TURN BACK CRITERIA	O	U
IF (TE) CONDITIONS ARE MET and IF (CT) SHOWS NO CURRENT	X	X
		X

LO_VOLT RELAY - CONTRLR (LITHONIA) (schedule)

AFTER ECM
 LAB WITH NO HOOD

DISCLAIMER: This drawing was prepared and is presented for communication purposes only and to aid building occupants in gaining a conceptual understanding of the revised systems. This drawing is in no way an engineering document or a part of the project design.

DRAWN BY	P. DAVIDS
REV 2	DATE 08-OCT-2013