



TO MAIN EXHAUST FANS ON ROOF

FROM AIR HANDLERS IN MECHANICAL ROOM

CONTRLR (SIEMENS)

Flow Control Maintains Room dP via Offset  
 Example:  
 1200 cfm SUPPLY  
 - 1100 cfm EXHAUST  
 -----  
 100 cfm OVERSUPPLY  
 (room is positive pressure)

CODE COMPLIANT  
 10 ACH

BEFORE ECM  
 LAB WITH NO HOOD

DISCLAIMER: This drawing was prepared and is presented for communication purposes only and to aid building occupants in gaining a conceptual understanding of the revised systems. This drawing is in no way an engineering document or a part of the project design.

DRAWN BY	P. DAVIDS
REV 2	DATE 08-OCT-2013